

# Certificate

SEBS-A.153337/12, V1.0

TÜV NORD Systems GmbH & Co. KG hereby certifies to

**Honeywell International Inc.  
Honeywell Field Products**

512 Virginia, Dr.  
Fort Washington, PA 19034, USA

that the safety-related

## SmartLine ST 700 HART Pressure Transmitter

is capable for safety related applications up to SIL 2, SIL 3 depending on the architecture and meets the requirements listed in the following standard.

IEC 61508: 2010;

Functional safety of

electrical/electronic/programmable

electronic safety-related systems;

Capable up to SIL 2 for single transmitter use;

Capable up to SIL 3 for multiple transmitter use

The certification is based on the valid version of report SEBS-A.153337/12TB.

This certificate entitles the holder to use the pictured Safety Approved mark.

Expiry date: 2018-01-21

Reference No.: G.SEB.BS.02.006.08.031



**Gerhard M. Rieger**  
Branch Manager  
Augsburg, 2013-01-21

